

iStop[®]

antifreeze valve
max. temperature 90°C



altecnic
CALEFFI group

iStop® antifreeze valve - 90°C max. temperature



Application

The iStop antifreeze valve allows the circuit medium to be drained when the temperature reaches an average of 3°C.

This prevents ice forming in the circuit of a system, generally with a heat pump, avoiding potential damage to equipment, valves and pipework.

The valves are suitable for a variety of fittings and pipes connected by a union.

Construction Details

Component	Material	Grade
Body:	Brass	BS EN 12164 CW724R
Body: 1½"	Brass	BS EN 12165 CW724R
Obturator:	Brass	BS EN 12164 CW617N
Springs:	Stainless steel	BS EN 10270-3 (AISI 302)
Seals:	EPDM	
Compression Nut:	Brass	BS EN 12165 CW617N
Olive:	Brass	BS EN 12164 CW614N


Technical Specification

Medium:	water	
Maximum working pressure:	10 bar	
Working temperature range:	0 to 90°C	
Ambient temperature range:	-30 to 60°C	
Medium temperature - opening:	3°C	
Medium temperature - closing:	4°C	
Accuracy:	±1°C	
Connection - compression:	BS EN 1254	
Connection threads:	BS EN ISO 228-1	
Kv - straight path:	22mm, 28mm & 1"	55 m³/hr
	1¼"	70 m³/hr
	1½"	72 m³/hr

Discharge Flow Rates

P - bar	T _{outside} - °C	Flow Rate - l/h
3	-5	0.5
	-20	1


Dimensions



Ref No	A	B	C	D
108202	Ø22	64	78.6	32
108302	Ø28	71	78	31
108602	G1	52	78.6	32
108702	G1¼	59	83	36
108802	G1½	62	83	36


Operating Principle

When the temperature of the water in the pipe drops below 3°C, the obturator of the antifreeze valve opens and drains off the water. The obturator closes when the medium temperature returns to 4°C.



Medium temperature >3°C
Obturator closed

Medium temperature <3°C
Valve being drained



iStop® antifreeze valve - 90°C max. temperature

Installation


The iStop valve must only be installed in a vertical position, with the outlet facing downwards, to allow the draining water to flow out and free from obstructions.

It is recommended to install the antifreeze valves on both the flow and return pipes, otherwise water may be left in one pipe which could then freeze.

The antifreeze valves must be installed outdoors, where the lowest temperatures can be reached if the heat pump is not operating.

They must also not be placed close to heat sources which could interfere with their function.


For the device to work properly, keep the system under pressure at all times, even when draining the antifreeze valve.



Presence of Traps

Do not make any trap connections.

If the shape of the connection pipes has the potential to create a trap effect (as shown below), part of the pipe will not be able to drain and frost protection will no longer be ensured.



Installation - Continued



Leave at least 15 cm clearance from the ground (fig. A) to prevent the block of ice which may form below from stopping water from draining from the valve.

Route the drain to a suitable collection point.

Keep a distance of at least 10 cm between the antifreeze valves (fig. B).


The valve must be free of insulation for the system to work properly.

When installed outdoors, the antifreeze valve must be protected from rain, snow and direct sunlight.



Vacuum Breaker Replacement

In the event of a malfunction, the vacuum breaker (1) can be replaced.



Thermostatic Cartridge Replacement

In the event of a malfunction, the thermostatic cartridge (2) can be replaced.

An automatic shut-off cock prevents the water from draining while the cartridge is being replaced, thereby keeping the system pressurised.

© Patents & Design Altecnic 2024

Altecnic Ltd retains all rights (including patents, designs and copyrights, trademarks and any other intellectual property rights) in relation to all information provided on or via the website, brochures or any other documents, including all texts, graphics and logos, contained on the website, in brochures or in any other documents published in the name of or on behalf of Altecnic Ltd in any form, without prior written consent of Altecnic Ltd.

Altecnic Ltd Mustang Drive, Stafford, Staffordshire ST16 1GW

T: +44 (0)1785 218200 E: sales@altecnic.co.uk

Registered in England No: 02095101

altecnic.co.uk

AL 512 03-06-24

E & O.E

© Altecnic Limited. 2024

ALTECNIC™

altecnic
CALEFFI group